Energy saving measures in heating, ventilation and air conditioning systems

Some <u>energy saving</u> measures in heating systems with expert assessments of energy saving potential are given in the table:

potential are given in the table:			
Nº	The content of the event	Assessment of energy saving potential	
1	Organization of accounting and control over the use of thermal energy	Up to 7 30% of thermal energy when installing apartment heat meters	
2	Reconstruction of the hot water treatment system	Saves up to 6% of fuel consumption	
3	Presence of systems of automatic regulation of temperature of the heat carrier depending on external temperature	Increase of temperature of air indoors over norm increases a heat expense by 4 ÷ 6%	
4	Elimination of drip leakage of water from shut-off valves	Leakage per year is 10 ÷ 35 m3 / year	
5	Presence of uninsulated shut-off valves	Losses equivalent to 1 m of uninsulated pipeline	
6	Installation of the regulator of heating on time	Saves up to 40% of heat consumption of the building	
7	Lowering the temperature in residential buildings at night	saves up to 2% of the building's heat consumption	
8	The presence of triple glazing windows.	Gives savings of up to 3 ÷ 4%	
9	The presence of vestibules and their partitioning at the entrances to the room and springs on the door	Saves up to 3 ÷ 4%	
10	The correct choice of color of heating devices	- coloring of the heating device with zinc paints increases heat transfer by up to 15%;	
		- oil painting reduces heat transfer by up to 8.5% (for cast iron radiator - reduces even more, up to 13%);	
		- covering of the heating device with decorative	

• <u>Mair</u>

• Ecology

[•] Energy saving directions

[•] Alternative energy

Energy saving measures in heating, ventilation and air conditioning systemsPublished on PATRIOT-NRG International portal for energy saving (http://patriot-nrg.com)

			plates, curtains - reduces heat transfer by up tp 10 ÷ 12%
11	Installation of radiator th	nermostats	Gives heat savings of up to $6 \div 7\%$
12	Installation of heat carr regulators for heating	ier temperature	The estimated savings will be about 15%.
13	Presence of block individual point	dual automated heating	Reduces heat consumption by 37% in industrial and administrative buildings and by 12% in residential buildings
14	Adjustment of heating a elevators and regulators debugging cards		The economic effect makes up to $15 \div 35\%$, and payback period - $1 \div 2$ years
15		Creating an infrared heating system	The use of radiant (infrared) heating in industrial buildings saves up to 25%
16		Installation of converters with mechanical heat removal	s Gives savings of up to 7%
17		Installation of air heating systems	g Saves up to 10 ÷ 15%
18		The use of glazed loggias.	Gives savings of 7 ÷ 40%
19		Elimination of cold bridges in places of connection of window covers with a wall	Gives economy of 2%
20		Sealing of cracks and leaks of window and door openings	Heat consumption after sealing of cracks and leaks is reduced by up to $10 \div 20\%$. 1 m. unsealed window porch is equal to the loss of 50 kWh for 228 days
21		Installation of windows with high thermal protection characteristics. Best: 1) triple glazing in wooden weaves	Heat saving 23%
• Main		2) the same with argon between the glass	34% compared to conventional double glazing

• Main

Energy saving directionsAlternative energy

[•] Ecology

Energy saving measures in heating, ventilation and air conditioning systemsPublished on PATRIOT-NRG International portal for energy saving (http://patriot-nrg.com)

22	Installation of double- glazed windows:	Use of the thermal screen allows to reduce heat losses through
	with heat-reflecting covering, or with two heat-reflecting coverings	windows from up to 22% in comparison with usual double glazing
23	The maximum possible savings of thermal energy with thermal insulation:	The implementation of measures will reduce the total heat loss
	exterior walls	42%
		4%
	cold floors	8%
	coating	
24	Replacement of tubular heat exchangers with plate ones	Saves about 15% of heat
25	Installation of a heat reflector, which is a heat insulating gasket with a reflective layer, between the heater and the wall	consumption
26	Restoration of thermal insulation on pipelines or heating and hot water systems	Allows to reduce heat f losses by 3 ÷ 9% of total consumption
27	Transfer of the heating system from the heat carrier "steam" to the heat carrier "hot water"	Savings of 20 ÷ 30% of heat
28	The presence of infiltration of cold air in heated rooms	Additional consumption of 10 ÷ 15 kcal per cubic meter of cold air
29	Introduction of the energy-saving mode of heat supply for heating from boiler-houses or CTP taking into account household heat emissions	Annual heat savings make up to 4 ÷ 17%
30	Introduction of facade regulation of heat supply taking into account meteorological factors (wind speed and solar radiation) effect of wind speed and solar radiation in the facade regulation, the annual	Overconsumption of thermal energy per year without meteorological factors (without facade regulation) in the range of wind speed change from 0 to the estimated is $6 \div 12\%$. Taking into account the combined

[•] Main

Energy saving directionsAlternative energy

[•] Ecology

Energy saving measures in heating, ventilation and air conditioning systems

Published on PATRIOT-NRG International portal for energy saving (http://patriot-nrg.com)

	savings can be 9 ÷ 18%	effect of wind speed and solar radiation in the facade regulation, the annual savings can be $9 \div 18\%$
31	Introduction of the economic schedule of supply of the heat carried taking into account the type of heating system and the type of heating devices	devices) of thermal loading at regulation of
32	Insulation of uninsulated pipelines of heat consumption systems located in basements and unheated rooms	Annual heat savings when insulating 1 m. A bare pipeline with an average diameter of 25 mm is 0.22 Gcal / m.

Energy saving measures in ventilation and air conditioning systems

Some **energy saving measures** in ventilation and air conditioning systems are given in the table. The list of these measures is significantly smaller than the list of **energy saving measures** in heating systems.

Energy saving in ventilation and air conditioning systems is represented by two parts: **savings of heat and electricity**. The **consumption of thermal energy** by these systems is almost an order of magnitude higher than the **consumption of electricity**. For industrial consumers, **heat and electricity consumption** are often correlated as 10: 1. However, given the high **cost** of air movement in <u>ventilation</u> and air conditioning systems, speaking of energy savings in these systems, we can not neglect the cost of electricity to create air flows.

It should also be borne in mind that the **savings in thermal energy** from the implementation of some of the above measures can be obtained by calculation.

Nº	Content of the event	Assessment of energy saving potential
1	Application of recirculation in ventilation and air conditioning systems	Savings depend on the degree of recirculation of exhaust air.
2	Application of air recovery on exhaust systems of ventilation and air conditioning	Gives savings of 20 - 70%. The savings depend on the efficiency of the recuperative heat exchanger-utilizer of exhaust air heat.
3	Application of recuperators with moisture transfer between exhaust and supply air	Increases economy in comparison with the utilizer of only obvious heat in addition to 30%
4	Application of air regeneration or exhaust ventilation and air	of the regenerative heat

- <u>Main</u>
- Energy saving directions
- Alternative energy
- Ecology

Energy saving measures in heating, ventilation and air conditioning systemsPublished on PATRIOT-NRG International portal for energy saving (http://patriot-nrg.com)

	conditioning systems	exchanger-utilizer of exhaust air heat.
5	Application of two recuperative air heat exchangers on supply and exhaust systems of ventilation and air conditioning	Savings depend on efficiency of system from two heat exchangers of utilizers of heat of exhaust air
6	Presence of automatic regulators on supply systems of ventilation	Gives up to 10% of economy of heat and 25 30% of the electric power
7	Thermal insulation of air ducts in places of laying with the lowered air temperature	
8	Application of frequency- regulated electric drive of fans for the purpose of regulation of an air expense	New optimum ways of quantitative regulation allow to reduce an expense of the on air movement in exhaust systems by 6 - 26% and in supply systems by 3 - 12% of size of consumption by the fan in the calculated mode
9	Joint use of general exchange and local ventilation in the form of local exhausts, air curtains, etc.	Savings are determined by calculation.
10	Localization of inflow and extraction (device of air oases, suppression, localization of inflow)	Reduction of air exchange at work of UPC by 25 - 50%
11	Elimination of suction and air leaks due to leaks in air ducts	Reduction of costs for air movement of fans by 9 - 10% (electricity)
12	Reduction of aerodynamic losses during air movement in air ducts	

Source URL: http://patriot-nrg.com/en/content/energy-saving-measures-heating-ventilation-and-airconditioning-systems

Energy saving directionsAlternative energy

• Ecology